



Product Service

CERTIFICATE

No. B 103722 0001 Rev. 00

Holder of Certificate: Dongguan Slocable Photovoltaic Technology Co., Ltd.

Huawei Scientific Valley NO.1
Xiangshan Road, Dalingshan Town
523812 Dongguan City, Guangdong Province
PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies):

103722

Certification Mark:



Product:

**Connector
(Connectors for Photovoltaic System)**

Model(s):

**CN40-CM, CN40-CM-01, CN40-PM,
BC40, BC50**

Parameters:

Rated Voltage: 1500 V d.c.
Rated Current: 40 A
Protection Class: II
Degree of Protection: IP68 (1m, 1h)
Ambient Temperature: -40 °C to +85 °C

Tested according to: IEC 62852(ed.1)
EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

64290190058601

Valid until:

2024-08-20

Date, 2019-08-21


(Symbol Zhao)